

DEPARTMENT OF HEALTH AND HUMAN SERVICES  
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 02/22/2012  
FORM APPROVED  
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  <b>475003</b>		(X2) MULTIPLE CONSTRUCTION A. BUILDING <b>01 - MAIN BUILDING 01</b> B. WING _____		(X3) DATE SURVEY COMPLETED  <b>03/30/2010</b>	
NAME OF PROVIDER OR SUPPLIER  <b>KINDRED TRANSITIONAL CARE &amp; REHAB BIRCHWOOD TER</b>				STREET ADDRESS, CITY, STATE, ZIP CODE <b>43 STARR FARM RD BURLINGTON, VT 05408</b>			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
K 000	INITIAL COMMENTS			K 000			
K 056 SS=C	<p>A Life Safety Code Survey was conducted at Birchwood Terrace on March 30, 2010. Accompanying the surveyor during the tour of the facility was the Maintenance Director.</p> <p>NFPA 101 LIFE SAFETY CODE STANDARD</p> <p>If there is an automatic sprinkler system, it is installed in accordance with NFPA 13, Standard for the Installation of Sprinkler Systems, to provide complete coverage for all portions of the building. The system is properly maintained in accordance with NFPA 25, Standard for the Inspection, Testing, and Maintenance of Water-Based Fire Protection Systems. It is fully supervised. There is a reliable, adequate water supply for the system. Required sprinkler systems are equipped with water flow and tamper switches, which are electrically connected to the building fire alarm system. 19.3.5</p> <p>This STANDARD is not met as evidenced by: Based on observation and confirmed by interview, the facility failed to assure sprinkler coverage met standard as required by NFPA 13.</p> <p>Per observation during the tour of the facility on March 30, 2010, that the sprinkler head is missing in the shed off the main boiler room.</p>			K 056			6/4/10

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Any deficiency statement ending with an asterisk (\*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.